


TABELA REGULACJI TEMPERATURY NOŚNIKA CIEPŁA DLA SIECI CIEPLNYCH ZASILANYCH Z ŹRÓDŁA :

TP1 Kazimierz Juliusz – Ciepłownia JULIUSZ, ul. Minerów 2, 41-215 Sosnowiec

Temperatura zewnętrzna	Temperatura zasilania	Temperatura powrotu	ΔT
Tzew [°C]	Tz [°C]	Tp [°C]	[°C]
-20	110	60	50
-19	109	60	49
-18	107	59	48
-17	106	59	47
-16	104	58	46
-15	103	58	45
-14	101	57	44
-13	100	57	43
-12	98	56	42
-11	97	56	41
-10	95	55	40
-9	93	55	38
-8	92	54	38
-7	90	54	36
-6	89	53	36
-5	87	53	34
-4	85	53	32
-3	84	52	32
-2	82	52	30
-1	81	51	30
0	79	51	28
1	78	50	28
2	76	50	26
3	74	49	25
4	73	49	24
5	71	48	23
6	70	48	22
7	68	47	21
8	66	47	19
9	65	46	19
10	63	46	17
11	62	45	17
12 i więcej	60	45	15

Dalkia Polska Energia S.A.
Dział Innowacji i Rozwoju

Andrzej Goździkowski